

2018 Consumer Confidence Report

Water System Name: Crescent Water Association

Report Date: June 14, 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2018 and may include earlier monitoring data.

Type of water source(s) in use: Well

Name & general location of source(s): Well #1 at 227 N. Magnolia Ave, Anaheim, CA

Drinking Water Source Assessment information: An assessment of the drinking water source for Crescent Water was completed in June 2002. The source is considered most vulnerable to the following activities not associated with contaminants detected in the water supply: Fertilizer, Pesticide/Herbicide application. In addition, the source is considered most vulnerable to the following activities not associated with any detected contaminants: Underground wastewater pipes. A copy of the complete assessment is available at the office of Victory Baptist Church.

Time and place of regularly scheduled board meetings for public participation:

Contact the office of Victory Baptist Church at (714) 220-1166 or email water@victoryanaheim.org.

For more information, contact: Joshua Mallipudi

Phone: (714) 220-1166 ext. 104

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER								
Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	9/2012	10	11 ppb	0	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	9/2012	10	.255 ppm		1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2017	57.4 ppm	57.4 ppm	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2017	459 ppm	459 ppm	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Radioactive Contaminants						
Gross Alpha Particle Activity (TOTa-U)	2018	7.49 pCi/L	7.49 pCi/L	15 pCi/L	0	Erosion of natural deposits
Uranium (NTUr)	2018	9.61 pCi/L	9.61 pCi/L	20 pCi/L	0.43	Erosion of natural deposits
Inorganic Contaminants						
Fluoride	2017	0.41 ppm	0.41 ppm	2 ppm	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (NO ₃)	2016	20.75 ppm	19.4 - 21.9 ppm	45 ppm	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite (NO ₃ NO ₂ -N)	2018	4.58 ppm	4.12 - 4.77 ppm	10 ppm	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate Nitrogen (NO ₃ -N)	2018	4.58 ppm	4.12 - 4.77 ppm	10 ppm	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Perchlorate (ClO ₄)	2012	2.13 ppb	ND-4.30 ppb	6 ppb	6	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.
Selenium	2009	5.50 ppb	5.50 ppb	50 ppb	(50)	Discharge from petroleum, glass and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Volatile Organic Contaminants						
1,1-Dichloroethene (11DCE)	2018	2.88 ppb	2.6 – 3.3 ppb	6 ppb	10	Discharge from industrial chemical factories
Trichloroethylene (TCE)	2018	1.12 ppb	1.1 – 1.2	5 ppb	1.7	Discharge from metal degreasing sites and other factories

Disinfection Byproducts, Disinfectant Residuals, and Disinfection Byproduct Precursors						
TTHMs Total Trihalomethanes	2014	6.2 ppb	6.2 ppb	80 ppb	N/A	By-product of drinking water chlorination
Chlorine	2018 (12 month average)	.57 ppm	0.20 – 1.07 ppm	MRDL 4.0 ppm	MRDLG 4.0 ppm	Drinking water disinfectant added for treatment

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Inorganic Contaminants						
Copper	See Table 2	See Table 2	See Table 2	1.0 ppm	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Chloride	2017	108 ppm	108 ppm	500 ppm	N/A	Runoff/leaching from natural deposits; seawater influence
Electrical Conductivity	2017	1,190 um/cm	1,190 um/cm	1600 um/cm	N/A	Substances that form ions when in water; seawater influence
Iron	2017	57.67 ppb	0 - 173 ppb	300 ppb	N/A	Leaching from natural deposits; industrial wastes
Sulfate SO ₄	2017	211 ppm	211 ppm	500 ppm	N/A	Runoff/leaching from natural deposits; industrial wastes
Turbidity	2017	.50 NTU	.50 NTU	TT	N/A	Soil runoff
Total Dissolved Solids TDS	2018	748 ppm	748 ppm	1000 ppm	N/A	Runoff/leaching from natural deposits

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
1,4 Dioxane (14DIOX)	2018	1.4 ppb	1.2 – 1.6 ppb	1.00 ppb	Some people who drink water containing 1,4 Dioxane in excess of the notification level over many years may have an increased risk of getting cancer.
Bicarbonate Alkalinity (as HCO ₃)	2017	281 mg/L	281 mg/L	N/A	N/A
Boron	2017	0.12 ppm	0.12 ppm	1 ppm	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
Bromide	2017	0.4 mg/L	0.4 mg/L	N/A	N/A
Calcium	2017	141 mg/L	141 mg/L	N/A	N/A
Hexavalent Chromium (CrVI)	2017	2.99 ug/L	2.99 ug/L	10 ug/L	Some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer.

Magnesium	2017	26.2 mg/L	26.2 mg/L	N/A	N/A
pH	2017	7.9 units	7.9 Units	N/A	N/A
Potassium	2017	4.6 mg/L	4.6 mg/L	N/A	N/A
Total Alkalinity – Bicarbonate (as CaCO ₃)	2017	230 mg/L	230 mg/L	N/A	N/A
Total Organic Carbon	2017	0.41 ppm	0.41 ppm	N/A	N/A
Vanadium	2017	3.50 ug/L	3.50 ug/L	50 ug/L	The babies of some pregnant women who drink water containing vanadium in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Crescent Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.


Consumer Confidence Report Certification Form

(To be submitted with a copy of the CCR)

Water System Name: Crescent Water Association

Water System Number: 3000811

The water system named above hereby certifies that its Consumer Confidence Report was distributed on June 14, 2019 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water (DDW).

Certified by: Name: Joshua Mallipudi
Signature: 
Title: Administrative Pastor,
Victory Baptist Church
Phone Number: (714) 220-1166 ext. 104 Date: June 14, 2019

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - Posting the CCR at the following URL: **www.victoryanaheim.org/resources**
 - Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - Advertising the availability of the CCR in news media (attach copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - Posted the CCR in public places **A complete copy of the 2018 CCR was posted outside the Fellowship Hall doors and the main office for everyone to read.**
 - Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
 - Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
 - Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
 - Other (attach a list of other methods used)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission